

Summary of FY2010 Operational Statistics

Run Identifier	Scheduled User Hours	Storage Ring Availability [hours]	Storage Ring Availability [%]	X-ray Availability [hours]	X-ray Availability [%]	Injector Availability	Faults	Mean Time to Recovery [hours]	Average Fill Duration without aFault [hours]	Faults Per Day of Delivered Beam	Delivered Integrated Current [A-hr]	Average Current [ma]
Run 09-3	1553.0	1535.8	98.9%	1535.8	98.9%	99.3%	11	1.57	139.6	0.17	154.5	100.6
Run 10-1	1727.0	1697.6	98.3%	1697.6	98.3%	98.2%	23	1.28	73.8	0.33	169.0	99.5
Run 10-2	1720.1	1691.4	98.3%	1691.4	98.3%	98.9%	15	1.91	112.8	0.21	170.1	100.6
Fiscal Year	5000.1	4924.8	98.5%	4924.8	98.5%	99.3%	49	1.54	100.5	0.24	493.5	100.2

Updated

9/15/2010

Data through end of Run 2010-1